

**TEST REPORT**

<b>Client Name/Address</b>	<b>TENSE Elektrik Elektronik San. Tic. A.Ş.</b> Muratpaşa Mah. Uluyol Cad. İşkent Sitesi E-F-G Blok No:29/E İç Kapı No:370 Bayrampaşa / İstanbul		
<b>Name and Identity of Test Item</b>	Over & Under Voltage Control Relay - GKV-12		
<b>Order No.</b>	<b>2301.20</b>	<b>Sample Acceptance Date</b>	<b>28.01.2023</b>
<b>Nam. Of Pages of The Report</b>	22 + 22 pages of annexes 44 pages in total	<b>Test Date(s)</b>	<b>28.01.2023-03.04.2023</b>
<b>Test Standard(s) Rating(s)</b>	TS EN IEC 60947-1: 12.04.2021 / TS EN 60947-5-1: 19.03.2018 Clause: 8.2, 8.3.3.3, 8.3.3.4, 8.3.3.5.3, 8.3.3.5.4, 8.3.4 Un: 3x380V AC, Ui: 380V, Uimp: 2.5kV, Ina: 5A, IP20 Detail(s) is/are given at the page 3.		
<b>Test Result(s)</b>	<b>POSITIVE / Details, are given on the following pages which are part of this report.</b>		

**Remarks**

TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2017 as test laboratory.


Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.


The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Tests marked in this test report (#) are not within the scope of accreditation obtained from TÜRKAK.



Date  
**14.04.2023**

Person in Charge of Test  
  
**Mehmet ŞUMNU**

Approval Date  
**14.04.2023**  
  
**Caner EREN**  
Laboratory Manager

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.  
Date format: dd.mm.yyyy